

# SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 443

Dated: 28.4.23

It is certified that an inspection team headed by AJAY SAHARAN (AEN)

(Name of Officers with designation) from P.H.E.D.

(Name of Department/ Office) inspected the Ambition Public School at Village - 15 SGR, PO. - Sardarpura Bika, Tehsil- Suratgarh, Dist.- Sriganganagar, Rajasthan on 28/04/2023 and found that the Ambition Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of 01 year

Signature with Seal: .....

Name : (अजय सहारण)

Designation : सहायक अभियंता

Name & Address of the Office / Department : जन स्वा० अभि० विभाग  
उपखण्ड सुरतगढ़


To

Ambition Public School, 15 SGR


Tehsil- Suratgarh, District- Sriganganagr

Rajasthan- 335804


(Name & Address of the Institution)



(Virender Singh)  
Principal  
Ambition Public School  
15 SGR, Suratgarh  
DDO:-105-524



(Rakesh)  
Secretary



MANAGER  
AMBITION PUBLIC SCHOOL  
15 SGR, SURATGARH (Raj)

OFFICE OF THE JUNIOR CHEMIST P. H. E. D.  
DISTRICT LABORATORY, SRIGANGANAGAR [RAJ]  
CHEMICAL EXAMINATION REPORT OF WATER SAMPLES

No:- JC/SGNR/CR-/23-24/ 272

Date:- 12/6/2023

To

Sh Rakesh Kumar  
Ambstion Public School,  
15-SGR

Tehsil:- Suratgarh

District- Sriganganagar

The chemical examination report of the sample collected by you is as under.

Ref:-Your letter no- 00

Date-09.06.2023

Collected by- Your Self

A.	Lab. Sample no.	Pc-38 (350)	Remarks
B.	Source	Tank-Tap	
C.	Location	Ambstion Public School	
D.	Village	15-SGR	
E.	Date of collection	08.06.2023	
F.	Date of receipt	09.06.2023	
G.	Date of examination	09.06.2023	
1	Ph	7.9	
2	Turbidity	01	
3	Colour	unobjectable	
4	Odour	unobjectable	
5	Alk.Phenopthalene(CaCo3)	0	
6	Alk.MethylOrange(CaCo3)	80	
7	Total Hardness (CaCo3)	100	
8.	Ca. Hardness	40	
9	Mg. Hardness	60	
10	Carbonate Hardness	80	
11	Non-Carbonate Hardness	20	
12	Chloride as Cl	20	
13	Nitrate as NO3	2	
14	Fluoride as F	0.32	
15	Total dissolved solids	190	
16	Residual Chlorine	0	

Remarks:- 1- Samples are not collected by laboratory.

2-Report is not valid for water quality legal cases.

Note : (1) Samples are not collected by laboratory.

(2) Report is not valid for water quality legal purposes.

*[Signature]*  
12/6/2023

Junior Chemist  
PHED Laboratory  
Sriganganagar

*[Signature]*

(Virender Singh) Principal  
Ambition Public School  
15 SGR, Suratgarh  
DDO:-105-524

*[Signature]*

(Rakesh) Secretary

*[Signature]*

MANAGER  
AMBITION PUBLIC SCHOOL  
15 SGR SURATGARH(Raj)